



COMMUNITY DEVELOPMENT DEPARTMENT
BUILDING & SAFETY DIVISION

2729 Prospect Park Drive | Rancho Cordova, CA 95670

Phone: (916) 851-8760

PermitServices@CityofRanchoCordova.org

Christmas Tree Sales Lot Information

Business License # _____ Permit # _____

Business Owner _____

Address _____

Doing Business As _____

Lot Address _____

Nearest Cross Street _____

Phone Number _____ Email _____

Will there be any yard lighting or Christmas tree lights on this lot? [] Yes [] No

Power will be supplied by: [] Existing circuit [] Temp. Power Pole [] Portable Generator

The following electrical standards are mandatory in City of Rancho Cordova Code under the provisions of the City of Rancho Cordova Electrical Code:

- 1. No electrical installation may be started unless the installer has secured an electric permit.
2. Strings of lighting above Christmas trees or the lot must clear the ground by a minimum of 10 feet above pedestrians and 18 feet above commercial areas, parking lots, agricultural, or other areas subject to truck traffic.
3. Where using cords, only Type S (heavy duty) cords may be used. No cords will be allowed to be routed across walkways. All connection boxes or plugs will be located at least 6 inches above ground. No electrical cords can be woven into metal fencing.
4. All electrical shall comply with the provisions of the CEC article 590 Temporary Installations.
5. When all electrical work has been completed, required inspections must be passed prior to allowing the public to enter the lot.

I, the undersigned licensee or authorized agent, understand that under penalty of perjury, if I violate any of these provisions, the business license for the Christmas tree sales at this location may be subject to revocation, and my right to sell Christmas trees at this location will terminate with the revocation of the business license.

Signature of Licensee or Authorized Agent

Date